

K. E. KLINGER  
FORESTER & FIRE WARDEN  
CHIEF ENGINEER  
FIRE PROTECTION DISTRICTS

# COUNTY OF LOS ANGELES

## FIRE DEPARTMENT

P.O. Box 3009, TERMINAL ANNEX  
LOS ANGELES 54, CALIFORNIA  
ANGELUS 97251

J. W. DUNCAN  
CHIEF ASSISTANT

G. M. ASHE  
BUSINESS MANAGER

February 4, 1957

RECEIVED

FEB 6 - 1957

DISTRICT 7.1

Los Angeles County Engineer  
Division of Building & Safety  
25422 South Narbonne Avenue  
Lomita, California

Attention Mr. Moore

Dear Sir:

In regard to the Gregory Built Rite Cabinet Shop located at 718 West Carson Street, the following agreements were reached at the time the building permit was issued:

1. That the installation of automatic sprinklers may be postponed until adequate water supply is available.
2. That fire extinguishers will be provided as required in N.B.F.U. Pamphlet No. 10 for Extra Hazardous Locations.

A representative of this Department will set up the fire extinguisher requirements and will give a clearance to the Division of Building and Safety when the extinguishers have been provided.

Very truly yours,

K. E. KLINGER  
County Forester and Fire Warden

By Leslie A. Sutton  
Assistant Chief  
Fire Prevention Bureau

LB:vd

cc: Gregory Built Rite Cabinets  
714 W. Carson Street  
Torrance, California

LOS ANGELES COUNTY

LETTERGRAM

To: H. H. Thompson - 7.1 From: R. V. Moore 7.1 Date: 1-29-57.Subject: 718 (714) W. Carson - Gregory Cabinet Shop No. \_\_\_\_\_

A phone check with the F.P.B. indicates that the checker turned up no record showing an abandon of this building, over 3000 sq. ft. as a cabinet shop without a sprinkler system.

Either the building should be used as a storage and assembly bldg. with ~~no spraying or painting~~ spraying or painting, only or the owner will have to obtain a written approval from this Division or the F.P.B. excusing the sprinkler system and relieving the cabinet works. Any electric approved shall be for the use approved only.

Moore.

9-26-56.

Completion soon.

Front bldg. pending correct vent  
for hanging heater, now clay pipe.

1-18-57

Sign on bldg. (near) 'Gregory's Cabinet Shop'  
Alerted inspector place has permit for  
storage only.

1-23-57

Inspector waiting to see owner.

1-28-57

Owner phoned me claiming he has approval  
from F.P.B.

1-29-57

F.P.B. checker has no such approval nothing in  
file. L.H.S.

J F M A M J J A S O N D

2-10-56

718  
W. Carson

Cabinet Shop - Assembly & Storage Only

Owner - Gregory \$15,700. Val.

This job was to be an ~~assembly~~

cabinet manufacturing but was too large and a sprinkling system could not be installed as water supply was insufficient, thus occup. was changed to 'Assembly & Storage' No power etc. yet - going well.

5-7-56

2-4-57

better to verify that F.P. Buell allow company with fire extinguishers as per their directive as water supply is inadequate for a sprinkler system. File closed.